

SITE NAME

Lightcloud Site


November 2018 USAGE

262.51 kWH

SITE ADDRESS

1 Main Street

ENERGY USAGE 2016



	USAGE LAST YEAR	USAGE THIS YEAR
January	0.0 kWH	0.0 kWH
February	0.0 kWH	0.0 kWH
March	0.0 kWH	0.0 kWH
April	0.0 kWH	0.0 kWH
May	0.0 kWH	0.0 kWH
June	0.0 kWH	402.98 kWH
July	0.0 kWH	1348.15 kWH
August	0.0 kWH	2011.82 kWH
September	0.0 kWH	2210.94 kWH
October	0.0 kWH	1928.6 kWH
November	0.0 kWH	241.71 kWH
December	0.0 kWH	0.0 kWH
Totals	0.00 kWH	8144.21 kWH

**Lightcloud Site
 Area & Zones Breakdown**

AREA NAME	AREA TOTAL	PERCENT OF SITE USAGE
Room #503 - Engineering	111.92 kWH	43.0 %
● File Room - Fix #1		21.43 kWH
● File Room - Fix #2		20.65 kWH
● Zone Controller E15F		1.59 kWH
● Zone Controller CA9E		1.36 kWH
● Other Zones		66.89 kWH
Room #507	20.26 kWH	8.0 %
● Zone Controller A191		1.33 kWH
● Zone Controller 7F8D		1.33 kWH
● Zone Controller ADDF		1.24 kWH
● Zone Controller CB46		1.20 kWH
● Other Zones		15.17 kWH
Room #501	16.06 kWH	6.0 %
● Zone Controller C9D5		0.91 kWH
● Zone Controller C99F		0.90 kWH
● Zone Controller B9E1		0.90 kWH
● Zone Controller B941		0.90 kWH
● Other Zones		12.44 kWH

5th Floor - Hallway

8.03 kWH

3.0 %

● Zone Controller F773	1.57 kWH
● Zone Controller 7EF8	1.19 kWH
● Zone Controller CA7A	1.18 kWH
● Zone Controller C9BA	1.16 kWH
● Other Zones	2.93 kWH

Room #502 - Files

6.77 kWH

3.0 %

● Zone Controller 3672	1.42 kWH
● Zone Controller 153B	1.08 kWH
● Zone Controller 1F88	1.04 kWH
● Zone Controller 1CB4	0.89 kWH
● Other Zones	2.34 kWH

Room #503 - Kitchen 513

5.24 kWH

2.0 %

● Zone Controller 1DC3	1.45 kWH
● Zone Controller BB3F	1.03 kWH
● Zone Controller 1CEE	0.96 kWH
● Zone Controller A1F8	0.91 kWH
● Other Zones	0.89 kWH

Room #503 - Office 512

4.92 kWH

2.0 %

● Zone Controller C774	0.94 kWH
● Zone Controller 7F34	0.92 kWH
● Zone Controller 1CF0	0.90 kWH
● Zone Controller C91C	0.80 kWH
● Other Zones	1.37 kWH

Room #506

4.33 kWH

2.0 %

● Zone Controller BDAF	0.58 kWH
● Zone Controller 1705	0.58 kWH
● Zone Controller BD6E	0.57 kWH
● Zone Controller 1E1E	0.57 kWH
● Other Zones	2.03 kWH

Director's Office

4.19 kWH

2.0 %

● Zone Controller CA14	0.92 kWH
● Zone Controller 7EF3	0.88 kWH
● Zone Controller 808D	0.77 kWH
● Zone Controller 7FE1	0.74 kWH
● Other Zones	0.88 kWH

Room #501 - Conference Room

3.95 kWH

2.0 %

● Zone Controller 1562	1.07 kWH
● Zone Controller F7C1	0.77 kWH
● Zone Controller 1D03	0.76 kWH
● Zone Controller C7B0	0.75 kWH
● Other Zones	0.60 kWH

Room #507 - Left Office

3.74 kWH

1.0 %

● #507 Left Office	0.95 kWH
● #507 Left Office	0.94 kWH
● #507 Left Office	0.92 kWH
● #507 Left Office	0.92 kWH



5th Floor - EM Lighting

3.74 kWH

1.0 %

 Hallway	1.57 kWH
 Zone Controller F54C	1.29 kWH
 Zone Controller 76E1	0.88 kWH
 Zone Controller F773	0.00 kWH
 Other Zones	0.00 kWH

Room #505

3.56 kWH

1.0 %

 Zone Controller CAE4	0.57 kWH
 Zone Controller 1D19	0.57 kWH
 Zone Controller C77D	0.56 kWH
 Zone Controller 7FE9	0.51 kWH
 Other Zones	1.35 kWH

Room #503 - Office 511

3.01 kWH

1.0 %

 Zone Controller E15B	0.91 kWH
 Zone Controller 7F1A	0.75 kWH
 Zone Controller B0CB	0.74 kWH
 Zone Controller BDA3	0.60 kWH

Room #501 - Office 506

2.84 kWH

1.0 %

 Zone Controller BEB8	1.12 kWH
 Zone Controller AE27	0.97 kWH
 Zone Controller CAE3	0.75 kWH
 Zone Controller 3855	0.00 kWH

Room #507 - Right Office

2.43 kWH

1.0 %

#507 Right Office	0.94 kWH
#507 Right Office	0.91 kWH
#507 Right Office	0.59 kWH
#507 Right Office	0.00 kWH

Room #503 - Office 510

2.09 kWH

1.0 %

Zone Controller E0B0	0.75 kWH
Zone Controller B951	0.75 kWH
Zone Controller C730	0.59 kWH
Zone Controller 1FDB	0.00 kWH
Other Zones	0.00 kWH

Temp

1.05 kWH

0.0 %

Zone Controller C7B1	1.05 kWH
Zone Controller CB9B	0.00 kWH
Zone Controller CB71	0.00 kWH
Zone Controller BE44	0.00 kWH
Other Zones	0.00 kWH

Room #507 - File Room

0.53 kWH

0.0 %



Zone Controller 1CEA	0.53 kWH
Zone Controller C764	0.00 kWH



Room #508

0.00 kWh

0.0 %

 Zone Controller E148	0.00 kWh
 Zone Controller C72A	0.00 kWh